

## SUBMITTAL COVER SHEET

### JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

### MODEL SUMMARY

<b>Quantity</b>	<b>Product</b>			
<b>Model</b>	<b>CBM-225</b>			
<b>Model #</b>	<b>5002</b>			
<b>Rating BTU</b>	<b>1 to 225,000 BTU's</b>			
<b>Rating GPH</b>	<b>1.70 GPH</b>			
<b>Inlet Port Size</b>	<b>¾"</b>			
<b>Outlet Port Size</b>	<b>¾"</b>			
<b>Clear Tube</b>	<b>Yes</b>			
<b>Opaque Tube</b>	<b>NO</b>			
<b>Translucent Tank</b>	<b>N/A</b>			
<b>Voltage</b>	<b>N/A</b>			
<b>Amps</b>	<b>N/A</b>			
<b>Watts</b>	<b>N/A</b>			
<b>Pump rating GPM</b>	<b>N/A</b>			

<b>pH Panel Model</b>	<b>Walchem</b>	<b>N/A</b>		
<b>Pump panel Model</b>	<b>SeeWater</b>	<b>N/A</b>		
<b>Tube Material</b>	<b>Polypropylene</b>	<b>YES</b>		
<b>Tank Material</b>	<b>Polyethylene</b>	<b>N/A</b>		
<b>Tube Temperature Rating</b>	<b>140F Con.</b>	<b>Yes</b>		
<b>Tank Temperature Rating</b>	<b>140F Con.</b>	<b>N/A</b>		
<b>Tank Frames</b>	<b>Powder coated</b>	<b>N/A</b>		
<b>Mounting</b>	<b>Horizontal</b>	<b>Yes</b>		
<b>Flue Drain Model</b>		<b>N/A</b>		
<b>Common Stack Model</b>		<b>N/A</b>		

**NOTES:**

Recommended Piping: Sch40 PVC or CPVC with unions  
Poly stranded with clamps