

Environmental Protection Agency

Section 40 CFR 403.5 (b) 2:

Specific prohibitions

“Pretreatment before drain”

“Pollutants which will cause corrosive structural damage to the **POTW, but in no case discharges with a **pH lower than 5.0**”**

(Publicly Owned Treatment Works)

The average pH level of condensing HVAC and hot water equipment with good combustion is 3.2 pH