

## SUBMITTAL COVER SHEET

### JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

### MODEL SUMMARY

Quantity		Clear Tube	Opaque Tube	
Model	JM-10	1007	1008	
Part #				
Rating BTU	601-1,000 MBH	Yes	Yes	
Rating GPH	8.0 Max. GPH	Yes	Yes	
Inlet Port Size	.75" Socket or Barb			
Outlet Port Size	.75" Socket or Barb			
Clear Tube		Yes	No	
Opaque Tube		NO	Yes	
Voltage	N/A			
Amps	N/A			
Watts	N/A			
Pump rating				

<b>pH Panel Model</b>	<b>Walchem</b>	<b>N/A</b>		
<b>Pump panel Model</b>	<b>Heatimer</b>	<b>N/A</b>		
<b>Tube Material</b>	<b>PVC Sch40</b>	<b>N/A</b>		
<b>Tank Material</b>	<b>Polypropylene</b>	<b>Yes</b>		
<b>Tube Temperature Rating</b>	<b>140F Con.</b>	<b>Yes</b>		
<b>Tank Frames</b>	<b>Powder coated</b>	<b>N/A</b>		
<b>Mounting</b>	<b>Horizontal Floor or Wall</b>	<b>Yes</b>		
<b>Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains</b>	<b>Yes</b>			
<b>Common Stack / Boiler</b>	<b>Yes</b>			

**NOTES:**

<p>Recommended Piping: Sch40 PVC, CPVC, Stainless Steel Poly stranded Tubing with clamps</p>
--------------------------------------------------------------------------------------------------

**Submitted By:**