

SUBMITTAL COVER SHEET

JIM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

MODEL SUMMARY

Quantity		Clear Tube	Opaque Tube	
Model	JM-20	1009	1010	
Part #				
Rating BTU	1,001-2,000 MBH	Yes	Yes	
Rating GPH	16.0 Max. GPH	Yes	Yes	
Inlet Port Size	.75" Socket or Barb			
Outlet Port Size	.75" Socket or Barb			
Clear Tube		Yes	No	
Opaque Tube		NO	Yes	
Voltage	N/A			
Amps	N/A			
Watts	N/A			

Pump rating	Shur-Flo	N/a		
pH Panel Model	Walchem	N/A		
Pump panel Model	Heatimer	N/A		
Tube Material	PVC Sch40	Yes		
Tank Material	Polypropylene	N/A		
Tube Temperature Rating	140F Con.	Yes		
Tank Frames	Powder coated	N/A		
Mounting	Horizontal Floor or Wall	Yes		
Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains	Yes			
Common Stack / Boiler	Yes			

NOTES:

<p>Recommended Piping: Sch40 PVC, CPVC, Stainless Steel Poly stranded Tubing with clamps</p>
--

Submitted By: