

SUBMITTAL COVER SHEET

JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

MODEL SUMMARY

Quantity		Clear Tube	Opaque Tube	
Model	JM-40	NO	YES	
Part #	1013			
Rating BTU	3,001-4,000 MBH	NO	Yes	
Rating GPH	32.0 GPH MAX	NO	Yes	
Inlet Port Size	1" Socket or Barb			
Outlet Port Size	1" Socket or Barb			
Clear Tube	N/A	NO		
Opaque Tube		NO	Yes	
Voltage	N/A			
Amps	N/A			
Watts	N/A			

Pump rating	Shur-Flo	N/a		
pH Panel Model	Walchem	N/A		
Pump panel Model	Heatimer	N/A		
Tube Material	PVC Sch40	Yes		
Tank Material	Polypropylene	N/A		
Tube Temperature Rating	140F Con.	Yes		
Tank Frames	Powder coated	N/A		
Mounting	Horizontal Floor or Wall	Yes		
Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains	Yes			
Common Stack / Boiler	Yes			

NOTES:

<p>Recommended Piping: Sch40 PVC, CPVC, Stainless Steel Poly stranded Tubing with clamps</p>
--

Submitted By: