

SUBMITTAL COVER SHEET

JIM BOILER WORKS, INC. / CONDENSATE PH TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

MODEL SUMMARY

Quantity		Clear Tube	Opaque	
Model	JM-6			
Part #		1005	1006	
Rating BTU	226-600 MBH			
Rating GPH		4.78 Max GPH	4.78 Max GPH	
Inlet Port Size	.75" Socket or Barb			
Outlet Port Size	.75" Socket or Barb			
Clear Tube		Yes	No	
Sch40 PVC		Yes	Yes	
Clean out Plug	Yes	Yes	Yes	
Voltage	N/A			
Amps	N/A			
Watts	N/A			
Pump rating GPM	N/A			

pH Panel Model	N/A	N/A		
Pump panel Model	N/A	N/A		
Tube Material	PVC Sch40			
Tank Material	N/A			
Tube Temperature Rating	140F Con.			
Tank Frames	N/A	N/A		
Mounting	Horizontal Floor or Wall			
Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains	Yes			
Common Stack / Boiler	Yes			

NOTES:

Recommended Piping: Sch40 PVC, CPVC, Stainless Steel
Poly stranded Tubing with clamps

Submitted By:

