

SUBMITTAL COVER SHEET

JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

MODEL SUMMARY

Quantity		Material		
Model	NB-4	Polypropylene		
Part #	2001			
Rating BTU	601-1,000 MBH			
Rating GPH	32.0 Max. GPH			
Inlet Port Size	1" FNPT			
Outlet Port Size	1" FNPT			
Vent	.75" FNPT			
Fill Port	Twist off 5"			
Voltage	N/A			
Amps	N/A			
Watts	N/A			

Pump rating				
pH Panel Model	Walchem	N/A		
Pump panel Model	Heatimer	N/A		
Tube Material	N/A	N/A		
Tank Material	Polypropylene			
Tank Temperature Rating	140F Con.			
Tank Frames	Powder coated	N/A		
Mounting	Horizontal Floor			
Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains	Yes			
Common Stack / Boiler	Yes			

NOTES:

<p>Recommended Piping: Sch40 PVC, CPVC, Stainless Steel Poly stranded Tubing with clamps</p>
--

Submitted By: