

SUBMITTAL COVER SHEET

JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

MODEL SUMMARY

Quantity		Material		
Model	NB-5LP	Polypropylene		
Part #	2002			
Rating BTU	4,000-5,000 MBH			
Rating GPH	40.0 GPH MAX			
Inlet Port Size	1" FNPT			
Outlet Port Size	1" FNPT (2) Each			
Vent	1" FNPT (2) Each			
Fill Port	36" Cover			
Design	Serpentine			
Baffles	YES			
Voltage	N/A			

Amps	N/A			
Watts	N/A			
Pump rating	N/A			
pH Panel Model	Walchem	N/A		
Pump panel Model	Heatimer	N/A		
Tube Material	N/A	N/A		
Tank Material	Polypropylene			
Tank Temperature Rating	140F Con.			
Tank Frames	Powder coated	N/A		
Mounting	Horizontal Floor			
Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains	Yes			
Common Stack / Boiler	Yes			

NOTES:

<p>Recommended Piping: Sch40 PVC, CPVC, Stainless Steel Poly stranded Tubing with clamps</p>
--

Submitted By: