

# SUBMITTAL COVER SHEET

## JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

### MODEL SUMMARY

Quantity		Material		
Model	NB-7	Polypropylene		
Part #	2004			
Rating BTU	4000-7000 MBH			
Rating GPH	56.0 Max. GPH			
Inlet Port Size	1" FNPT			
Outlet Port Size	1" FNPT			
Vent	.75" FNPT			
Fill Port	Twist off 5"			
Voltage	N/A			
Amps	N/A			
Watts	N/A			

<b>Pump rating</b>				
<b>pH Panel Model</b>	<b>Walchem</b>	<b>N/A</b>		
<b>Pump panel Model</b>	<b>Heatimer</b>	<b>N/A</b>		
<b>Tube Material</b>	<b>N/A</b>	<b>N/A</b>		
<b>Tank Material</b>	<b>Polypropylene</b>			
<b>Tank Temperature Rating</b>	<b>140F Con.</b>			
<b>Duel Parallel Tanks</b>	<b>Yes</b>			
<b>Tank Footings</b>	<b>Steel Strut Painted</b>	<b>YES</b>		
<b>Mounting</b>	<b>Horizontal Floor</b>			
<b>Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains</b>	<b>Yes</b>			
<b>Common Stack / Boiler</b>	<b>Yes</b>			

**NOTES:**

<p>Recommended Piping: Sch40 PVC, CPVC, Stainless Steel Poly stranded Tubing with clamps</p>
--

**Submitted By:**