

SUBMITTAL COVER SHEET

JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

MODEL SUMMARY

Quantity		Material		
Model	NB-9	Polypropylene		
Part #	2005			
Rating BTU	4000-9000 MBH			
Rating GPH	72.00 Max. GPH			
Inlet Port Size	1" FNPT			
Outlet Port Size	1" FNPT			
Vent	.75" FNPT			
Fill Port	Twist off 5"			
Voltage	N/A			
Amps	N/A			
Watts	N/A			

Pump rating				
pH Panel Model	Walchem	N/A		
Pump panel Model	Heatimer	N/A		
Tube Material	N/A	N/A		
Tank Material	Polypropylene			
Tank Temperature Rating	140F Con.			
Duel Parallel Tanks	Yes			
Tank Footings	Steel Strut Painted	YES		
Mounting	Horizontal Floor			
Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains	Yes			
Common Stack / Boiler	Yes			

NOTES:

<p>Recommended Piping: Sch40 PVC, CPVC, Stainless Steel Poly stranded Tubing with clamps</p>
--

Submitted By: