

# SUBMITTAL COVER SHEET

## JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

### MODEL SUMMARY

<b>Quantity</b>				
<b>Model</b>	<b>NBT-610</b>			
<b>Part #</b>	<b>2010</b>			
<b>Rating BTU</b>	<b>600-1500 MBH</b>			
<b>Rating GPH</b>	<b>11.0 GPH Max</b>			
<b>Inlet Port Size</b>	<b>.75" Socket or Barb</b>			
<b>Outlet Port Size</b>	<b>.75" Socket or Barb</b>			
<b>Clear Cover</b>	<b>Yes</b>			
<b>PP Tank</b>	<b>Yes</b>			
<b>Light Grey Tank</b>	<b>Yes</b>			
<b>Voltage</b>	<b>N/A</b>			
<b>Amps</b>	<b>N/A</b>			
<b>Watts</b>	<b>N/A</b>			

<b>Pump rating GPM</b>	N/A			
<b>pH Panel Model</b>	Walchem	N/A		
<b>Pump panel Model</b>	Heatimer	N/A		
<b>Tube Material</b>	PVC Sch40	N/A		
<b>Tank Material</b>	Polypropylene	Yes		
<b>Tank Temperature Rating</b>	140F Con.	Yes		
<b>Tank Temperature Rating</b>	140F Con.	Yes		
<b>Tank Frames</b>	Powder coated	N/A	N/A	
<b>Mounting</b>	Horizontal Floor	Yes		
<b>Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains</b>	Yes			
<b>Common Stack / Boiler</b>	Yes			

**NOTES:**

Recommended Piping: Sch40 PVC, CPVC, Stainless Steel  
Poly stranded Tubing with clamps

**Submitted By:**