

August 16, 2016

JJM BOILER WORKS, INC.
NEUTRALIZER CONDENSATE TUBES

“Filler Replacement Instructions”

Model V-250 & V-250 Combi

ALL WORK MUST BE DONE BY AN EXPERIENCED HEATING TECHNICIAN.

1. Rubber or plastic gloves, eye protection, and breathing mask must be worn.
2. The neutralizing Pellet Media must be changed on a yearly basis at minimum or when the outlet pH falls below 5.0 pH.
3. Remove power from the boiler, hot water heater, or furnace.
4. Remove outer canister by twisting it clockwise.
5. Remove inner cartridge and dispose of properly.
6. Clean out any sediment at the bottom of the outer canister. Insert new replacement pre-charged cartridge. Be sure “O” ring is in place.
7. Return the entire unit back to the neutralizer cap by twisting it on snug counter clockwise.
8. Check and clean the P trap and all drain lines connected to the condensate drain system.
9. Dispose of any old Media, this material is non-hazardous.
10. Safety Data Sheets can be found on our web site www.jjmboilerworks.com
11. Return power to the heating unit and check the tube and lines for proper flow and any leakage.