

SUBMITTAL COVER SHEET

JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

MODEL SUMMARY

Quantity		Material		
Model	TCP-3200	Polypropylene		
Part #	9000			
Rating BTU	32,000 MBH			
Rating GPH	256.0 GPH Max			
Inlet Port Size	3/4" Manifold			
Outlet Port Size	1-1/4" FNPT			
Vent	.75"			
Fill Port	6" / 800 Micron Bags			
Voltage	115 / 1/60			
Amps	2.1 Total			
Watts	N/A			

Pump rating	1.4 GPM / each pump			
pH Panel Model	Walchem	Optional		
Pump panel Model	Taco / 3 Zone			
Tube Material	Poly			
Tank Material	Polypropylene			
Tank Temperature Rating	140F Con.			
Active Media	Magnesium Hydroxide Pellets	33# per Cell		
Mounting	Horizontal Floor			
Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains	Yes			
Common Stack / Boiler	Yes			

NOTES:

Recommended Piping: Sch40 PVC, CPVC, Stainless Steel
Poly stranded Tubing with clamps

Submitted By: