

SUBMITTAL COVER SHEET

JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

MODEL SUMMARY

Quantity	Product			
Model	V-252			
Model #	4006			
Rating BTU	1 to 500,000 BTU's			
Rating GPH	3.80 GPH			
Inlet Port Size	¾"			
Outlet Port Size	¾"			
Clear Tube	Yes			
Inner Cartridge	Yes			
Active Ingredient	Magnesium Hydroxide Pellets			
Voltage	N/A			
Amps	N/A			
Watts	N/A			

Pump rating GPM	N/A			
pH Panel Model	Walchem	N/A		
Pump panel Model	SeeWater	N/A		
Tube Material	Polypropylene	YES		
Tank Material	Polyethylene	N/A		
Tube Temperature Rating	140F Con.	Yes		
Tank Temperature Rating	140F Con.	N/A		
Tank Frames	Powder coated	N/A		
Mounting	Horizontal	Yes		
Flue Drain Model		N/A		
Common Stack Model		N/A		

NOTES:

Recommended Piping: Sch40 PVC, CPVC, PP Tubing

